	Document Title: Impact Performance Certification Authorization Report	Doc No: FRM B1-43	
		Rev No: 3	Page: 1 Of: 1
Required By: PRO B1-03			

CAR & Product ID Number: 190 - 502

Issue Date: 01/20/2015

Revision Date: 01/20/2015

Expiration Date: 01/12/2019

Company Code: 190

This Certification Authorization Report (CAR) is issued by Keystone Certifications, Inc. (KCI) after full validation review of the product qualification documents for the product named below. This report is only valid when signed by an officer of KCI, and indicates the product as manufactured by the company named below has been tested and meets the requirements of the referenced standard and is eligible for the application of Keystone Certification Program certification labels. Licensee stipulates in affixing certification labels to products, that those products are representative of the specimen evaluated and documented for certification authorization. Only products bearing such a certification label shall be considered certified. The information in this report can be verified at www.keystonecerts.com.

Licensee Information:	Product Information:
PGT Industries 1070 Technology Dr. PO Box 1529 Nokomis, FL 34274	Model: AW5540 PVC Impact Awning Operator Type: AP Config: All/Snub, GS-5/16" Ann Lami IG Max Width: 60 Max Height: 42 Corresponding Structural CARs: 190-1065.0

Referenced Standard:	Product Rating:
ASTM E1886-05/E1996-12	Missile Level D, Wind Zone 4, DP=+/-50, 60x42

Qualifying Test Information:	
Test Report No:	FTL-8149/8150/8151
Test Report Expiration:	01/12/2019

Authorized Signature:




Keystone Certifications, Inc.

564 Old York Road, Suite 5

Etters, Pennsylvania 17319

Phone: 717-932-8500

Fax: 717-932-8501

	Document Title: Impact Performance Certification Authorization Report	Doc No: FRM B1-43	
		Rev No: 3	Page: 1 Of: 1
Required By: PRO B1-03			

CAR & Product ID Number: 190 - 503

Issue Date: 01/20/2015

Revision Date: 01/20/2015

Expiration Date: 01/13/2019

Company Code: 190

This Certification Authorization Report (CAR) is issued by Keystone Certifications, Inc. (KCI) after full validation review of the product qualification documents for the product named below. This report is only valid when signed by an officer of KCI, and indicates the product as manufactured by the company named below has been tested and meets the requirements of the referenced standard and is eligible for the application of Keystone Certification Program certification labels. Licensee stipulates in affixing certification labels to products, that those products are representative of the specimen evaluated and documented for certification authorization. Only products bearing such a certification label shall be considered certified. The information in this report can be verified at www.keystonecerts.com.

Licensee Information:	Product Information:
PGT Industries 1070 Technology Dr. PO Box 1529 Nokomis, FL 34274	Model: AW5540 PVC Impact Awning Operator Type: AP Config: All/Snub, GS-5/16" Ann Lami IG Max Width: 52 Max Height: 42 Corresponding Structural CARs: 190-1066.0

Referenced Standard:	Product Rating:
ASTM E1886-05/E1996-12	Missile Level D, Wind Zone 4, DP=+65/-70, 52x42

Qualifying Test Information:	
Test Report No:	FTL-8153/8154
Test Report Expiration:	01/13/2019

Authorized Signature:




Keystone Certifications, Inc.

564 Old York Road, Suite 5

Etters, Pennsylvania 17319

Phone: 717-932-8500

Fax: 717-932-8501

	Document Title: Structural Performance Certification Authorization Report	Doc No: FRM B1-02	
		Rev No: 6	Page: 1 Of: 1
Required By: PRO B1-03			

CAR & Product ID Number: 190 - 1065
Issue Date: 01/19/2015
Revision Date: 01/19/2015
Expiration Date: 01/12/2019
Licensee Code: 190


This Certification Authorization Report (CAR) is issued by Keystone Certifications, Inc. (KCI) after full validation review of the product specification documents for the product named below. This report is only valid when signed by an officer of KCI, and indicates the product as manufactured by the company named below has been tested and meets the requirements of the referenced standard and is eligible for the application of Keystone Certification Program certification labels. The licensee stipulates in affixing certification labels to products, that those products are representative of the specimen evaluated and documented for certification authorization. Only products bearing such a certification label shall be considered certified. The information in this report can be verified at www.keystonecerts.com.

Licensee Information:	Product Information:
PGT Industries 1070 Technology Dr. PO Box 1529 Nokomis, FL 34274	Model Name: AW5540 PVC Impact Awning Operator Type: AP Configuration: All/Snub, GS-5/16" Ann Lami IG Max. Width: 60 Max. Height: 42


Referenced Standard:	Product Rating:
AAMA/WDMA/CSA 101/I.S.2/A440-11	Class LC-PG50 1524x1067 (60x42)-Type AP WTP=9.75

Qualifying Test Information:	
Test Report No:	FTL-8148
Test Report Expiration:	01/12/2019

Authorized Signature:



Keystone Certifications, Inc.
564 Old York Road, Suite 5
Etters, Pennsylvania 17319
Phone: 717-932-8500
Fax: 717-932-8501

	Document Title: Structural Performance Certification Authorization Report	Doc No: FRM B1-02	
		Rev No: 6	Page: 1 Of: 1
Required By: PRO B1-03			

CAR & Product ID Number: 190 - 1066
Issue Date: 01/20/2015
Revision Date: 01/20/2015
Expiration Date: 01/13/2019
Licensee Code: 190


This Certification Authorization Report (CAR) is issued by Keystone Certifications, Inc. (KCI) after full validation review of the product specification documents for the product named below. This report is only valid when signed by an officer of KCI, and indicates the product as manufactured by the company named below has been tested and meets the requirements of the referenced standard and is eligible for the application of Keystone Certification Program certification labels. The licensee stipulates in affixing certification labels to products, that those products are representative of the specimen evaluated and documented for certification authorization. Only products bearing such a certification label shall be considered certified. The information in this report can be verified at www.keystonecerts.com.

Licensee Information:	Product Information:
PGT Industries 1070 Technology Dr. PO Box 1529 Nokomis, FL 34274	Model Name: AW5540 PVC Impact Awning Operator Type: AP Configuration: All/Snub, GS-5/16" Ann Lami IG Max. Width: 52 Max. Height: 42

Referenced Standard:	Product Rating:
AAMA/WDMA/CSA 101/I.S.2/A440-11	Class LC-PG65 1324x1067 (52x42)-Type AP Neg DP=70

Qualifying Test Information:	
Test Report No:	FTL-8152
Test Report Expiration:	01/13/2019

Authorized Signature:



Keystone Certifications, Inc.

564 Old York Road, Suite 5
Etters, Pennsylvania 17319
Phone: 717-932-8500
Fax: 717-932-8501