	Document Title: Impact Performance Certification Authorization Report	Doc No: FRM B1-43	
		Rev No: 4	Page: 1 Of: 1
Required By: PRO B1-03			

CAR & Product ID Number: 190 - 285
Issue Date: 11/11/2014
Revision Date: 11/17/2014
Expiration Date: 10/1/2018
Company Code: 190

This Certification Authorization Report (CAR) is issued by Keystone Certifications, Inc. (KCI) after full validation review, and is based on a standardized evaluation of the product conducted by an independent accredited laboratory in accordance with the specified referenced standard. Actual fenestration product performance may vary based on many factors, including installation, condition of the wall/roof substrate and the age of the product and installation components.

This report indicates the product is eligible for the application of Keystone Certification Program certification labels. Licensee stipulates in affixing certification labels to products, that those products are representative of the specimen evaluated and documented for certification authorization. Only products bearing such a certification label shall be considered certified. The information in this report can be verified at www.keystonecerts.com.

Licensee Information: PGT Industries 1070 Technology Dr. PO Box 1529 Nokomis FL 34274	Product Information: Model: SH5500 View PVC Imp Single Hung Operator Type: H Config: EM/All, GS-5/16" Ann Lami IG Max Width: 52 Max Height: 92 Corresponding Structural CARs: 190-1028.0
--	---

Referenced Standard: ASTM E1886-05/E1996-12	Product Rating: Missile Level D, Wind Zone 4, DP=+/-50, 52x92
---	---

Qualifying Test Information:	
Test Report No:	FTL-7951/7952/7953
Test Report Expiration:	10/1/2018


Authorized Signature:

St 2 21

Digitally signed by Steven M. Urich
DN: cn=Steven M. Urich, o=Keystone
Certifications, Inc., ou,
email=surich@keystonecerts.com, c=US
Date: 2014.11.17 15:50:00 -05'00'

Keystone Certifications, Inc.

564 Old York Road, Suite 5
Etters, Pennsylvania 17319
Phone: 717-932-8500
Fax: 717-932-8501

	Document Title: Impact Performance Certification Authorization Report	Doc No: FRM B1-43	
		Rev No: 4	Page: 1 Of: 1
Required By: PRO B1-03			

CAR & Product ID Number: 190 - 286
Issue Date: 11/17/2014
Revision Date: 11/17/2014
Expiration Date: 10/6/2018
Company Code: 190

This Certification Authorization Report (CAR) is issued by Keystone Certifications, Inc. (KCI) after full validation review, and is based on a standardized evaluation of the product conducted by an independent accredited laboratory in accordance with the specified referenced standard. Actual fenestration product performance may vary based on many factors, including installation, condition of the wall/roof substrate and the age of the product and installation components.

This report indicates the product is eligible for the application of Keystone Certification Program certification labels. Licensee stipulates in affixing certification labels to products, that those products are representative of the specimen evaluated and documented for certification authorization. Only products bearing such a certification label shall be considered certified. The information in this report can be verified at www.keystonecerts.com.

Licensee Information: PGT Industries 1070 Technology Dr. PO Box 1529 Nokomis FL 34274	Product Information: Model: SH5500 View PVC Imp Single Hung Operator Type: H Config: EM/All, GS-5/16" Ann Lami IG Max Width: 52 Max Height: 92 Corresponding Structural CARs: 190-1029.0
--	---

Referenced Standard: ASTM E1886-05/E1996-12	Product Rating: Missile Level D, Wind Zone 4, DP=+65/-70, 52x92
---	---

Qualifying Test Information:	
Test Report No:	FTL-7954/7955/7956
Test Report Expiration:	10/6/2018


Authorized Signature:

St 2 21

Digitally signed by Steven M. Urich
DN: cn=Steven M. Urich, o=Keystone
Certifications, Inc., ou,
email=surich@keystonecerts.com, c=US
Date: 2014.11.17 15:50:23 -05'00'

Keystone Certifications, Inc.

564 Old York Road, Suite 5
Etters, Pennsylvania 17319
Phone: 717-932-8500
Fax: 717-932-8501

	Document Title: Structural Performance Certification Authorization Report	Doc No: FRM B1-02	
		Rev No: 7	Page: 1 Of: 1
Required By: PRO B1-03			

CAR & Product ID Number: 190 - 1028.0
Issue Date: 11/11/2014
Revision Date: 11/17/2014
Expiration Date: 10/2/2018
Company Code: 190

This Certification Authorization Report (CAR) is issued by Keystone Certifications, Inc. (KCI) after full validation review, and is based on a standardized evaluation of the product conducted by an independent accredited laboratory in accordance with the specified referenced standard. Actual fenestration product performance may vary based on many factors, including installation, condition of the wall/roof substrate and the age of the product and installation components.

This report indicates the product is eligible for the application of Keystone Certification Program certification labels. Licensee stipulates in affixing certification labels to products, that those products are representative of the specimen evaluated and documented for certification authorization. Only products bearing such a certification label shall be considered certified. The information in this report can be verified at www.keystonecerts.com.

Licensee Information:	Product Information:
PGT Industries 1070 Technology Dr. PO Box 1529 Nokomis FL 34274	Model: SH5500 View PVC Imp Single Hung Operator Type: H Config: EM/All, GS-5/16" Ann Lami IG Max Width: 52 Max Height: 92

Referenced Standard:	Product Rating:
AAMA/WDMA/CSA 101/I.S.2/A440-11	Class LC-PG50 1324x2330 (52x92)-Type H


Qualifying Test Information:	
Test Report No:	FTL-7949
Test Report Expiration:	10/2/2018

Authorized Signature:



Digitally signed by Steven M. Ulrich
DN: cn=Steven M. Ulrich, o=Keystone
Certifications, Inc., ou,
email=surich@keystonecerts.com,
c=US
Date: 2014.11.17 15:55:24 -05'00'

Keystone Certifications, Inc.
564 Old York Road, Suite 5
Etters, Pennsylvania 17319
Phone: 717-932-8500
Fax: 717-932-8501

	Document Title: Structural Performance Certification Authorization Report	Doc No: FRM B1-02	
		Rev No: 7	Page: 1 Of: 1
Required By: PRO B1-03			

CAR & Product ID Number: 190 - 1029.0

Issue Date: 11/11/2014

Revision Date: 11/17/2014

Expiration Date: 10/1/2018

Company Code: 190

This Certification Authorization Report (CAR) is issued by Keystone Certifications, Inc. (KCI) after full validation review, and is based on a standardized evaluation of the product conducted by an independent accredited laboratory in accordance with the specified referenced standard. Actual fenestration product performance may vary based on many factors, including installation, condition of the wall/roof substrate and the age of the product and installation components.

This report indicates the product is eligible for the application of Keystone Certification Program certification labels. Licensee stipulates in affixing certification labels to products, that those products are representative of the specimen evaluated and documented for certification authorization. Only products bearing such a certification label shall be considered certified. The information in this report can be verified at www.keystonecerts.com.

Licensee Information:	Product Information:
PGT Industries 1070 Technology Dr. PO Box 1529 Nokomis FL 34274	Model: SH5500 View PVC Imp Single Hung Operator Type: H Config: EM/All, GS-5/16" Ann Lami IG Max Width: 52 Max Height: 92

Referenced Standard:	Product Rating:
AAMA/WDMA/CSA 101/I.S.2/A440-11	Class LC-PG65 1324x2330 (52x92)-Type H Neg DP=70

Qualifying Test Information:	
Test Report No:	FTL-7950
Test Report Expiration:	10/1/2018

Authorized Signature:

St 2 21

Digitally signed by Steven M. Urich
DN: cn=Steven M. Urich, o=Keystone
Certifications, Inc., ou,
email=surich@keystonecerts.com,
c=US
Date: 2014.11.17 15:55:47 -05'00'

Keystone Certifications, Inc.

564 Old York Road, Suite 5
Etters, Pennsylvania 17319
Phone: 717-932-8500
Fax: 717-932-8501