

Document Title:

Structural Performance Certification Authorization Report

Doc No: FRM B1-02				02	
Rev No:	7	Page:	1	Of:	1

Required By:

PRO B1-03

CAR & Product ID Number:

190 - 1011.0

Issue Date:

10/2/2014

Revision Date:

11/7/2014

Expiration Date:

7/00/00/0

- Aprilation Date

7/29/2018

Company Code:

190

This Certification Authorization Report (CAR) is issued by Keystone Certifications, Inc. (KCI) after full validation review, and is based on a standardized evaluation of the product conducted by an independent accredited laboratory in accordance with the specified referenced standard. Actual fenestration product performance may vary based on many factors, including installation, condition of the wall/roof substrate and the age of the product and installation components.

This report indicates the product is eligible for the application of Keystone Certification Program certification labels. Licensee stipulates in affixing certification labels to products, that those products are representative of the specimen evaluated and documented for certification authorization. Only products bearing such a certification label shall be considered certified. The information in this report can be verified at www.keystonecerts.com.

Licensee Information:	Product Information:	
PGT Industries	Model: 5420/5440 PVC Fixed	
1070 Technology Dr. PO Box 1529	Operator Type: FW	
Nokomis FL 34274	Config: No	
	Max Width: 96	
	Max Height: 63	

Referenced Standard:	Product Rating:
AAMA/WDMA/CSA 101/I.S.2/A440-11	Class CW-PG50 2438x1600 (96x63)-Type FW WTP=10.5

Qualifying Test Information:			
Test Report No:	FTL-7959		
Test Report Expiration:	7/29/2018		

Authorized Signature:

1t 2 21

Digitally signed by Steven M. Urich DN: cn=Steven M. Urich, o=Keystone Certifications, Inc., ou, email=surich@keystonecerts.com, c=US

Date: 2014.11.10 11:15:24 -05'00'

Keystone Certifications, Inc.

564 Old York Road, Suite 5 Etters, Pennsylvania 17319 Phone: 717-932-8500

Fax: 717-932-8500



Structural Performance Certification **Authorization Report**

Doc No:	FRM B1-02				
Rev No:	7	Page:	1	Of:	1

Required By:

PRO B1-03

CAR & Product ID Number:

190 - 1017.0

Issue Date:

11/6/2014

Revision Date:

12/17/2014

Expiration Date:

8/12/2018

Company Code:

190

This Certification Authorization Report (CAR) is issued by Keystone Certifications, Inc. (KCI) after full validation review, and is based on a standardized evaluation of the product conducted by an independent accredited laboratory in accordance with the specified referenced standard. Actual fenestration product performance may vary based on many factors, including installation, condition of the wall/roof substrate and the age of the product and installation components.

This report indicates the product is eligible for the application of Keystone Certification Program certification labels. Licensee stipulates in affixing certification labels to products, that those products are representative of the specimen evaluated and documented for certification authorization. Only products bearing such a certification label shall be considered certified. The information in this report can be verified at www.keystonecerts.com.

Licensee Information:	Product Information:	
PGT Industries	Model: 5420/5440 PVC Fixed	
1070 Technology Dr. PO Box 1529	Operator Type: FW	
Nokomis FL 34274	Config: No, GS-3/16" Temp IG	
	Max Width: 120	
	Max Height: 60	

Referenced Standard:	Product Rating:		
AAMA/WDMA/CSA 101/I.S.2/A440-11	Class CW-PG70 3048x1524 (120x60)-Type FW		

Qualifying Test Inform	nation:
Test Report No:	FTL-7891/8167
Test Report Expiration:	8/12/2018

Authorized Signature:

It 2 21

Digitally signed by Steven M. Urich DN: cn=Steven M. Urich, o=Keystone Certifications, Inc., ou, email=surich@keystonecerts.com, c=US

Date: 2014.12.17 13:30:31 -05'00'

Keystone Certifications, Inc.

564 Old York Road, Suite 5 Etters, Pennsylvania 17319 Phone: 717-932-8500

Fax: 717-932-8501